EOHU Eastern Ontario Health Unit | BSEO Bureau de santé de l'est de l'Ontario

PUBLIC SPA RECORD

Date: _____

DAILY INSPECTION *30 minutes prior to opening the public pool*	
Time:	**Initials:**
☐ **Emergency Telephone & Sign** ☐ **Safety Equipment*** ☐ **ORP*** 600–900mV: _____ mV	
Total # of Bathers: _____ **x15 L:** _____ **Daily Make-Up Water Required:** _____	
Daily Make-up Water Added: _____ - _____ = _____ **Today's Reading** **Previous Day's Reading** **Total Water Added**	

***Safety Equipment** may include first aid kit, spine board, non-conducting reaching pole, 2 buoyant throwing aids and relevant signage.

***ORP** is to be documented for premises using automatic sensing devices.

WATER CHEMISTRY

If Automatic Sensing Device is used, test water chemistry 30 minutes prior to opening and then every 4 hours.
If NO Automatic Sensing Device is used, test water chemistry 30 minutes prior to opening and then every 2 hours.

Time	Water Temperature (max. 40°C)	Free Available Chlorine (FAC) 5–10.0 ppm	Total Chlorine **OR** Total Bromine 5.0–10.0 ppm	pH 7.2–7.8	Total Alkalinity 60–180 ppm	Water Clarity (black disc visible from 9 m)	# Bathers	Initials

If you require this information in an alternate format, please call 1-800-267-7120 and press 0.

OTHER DAILY RECORDS
Records of accidents, injuries, rescues, and safety equipment breakdowns:
Records of maintenance and chemicals added:
Records of spa drainage, inspection, and refills:

OUTDOOR SPAS ONLY – WEEKLY WATER CHEMISTRY		
Date & Time	**Cyanuric Acid (CYA) Less than 60 ppm**	**Initials**

MONTHLY INSPECTION					
Date & Time	**Emergency Stop Button**	**Water, Gravity & Suction Outlet Covers**	**Ground Fault Circuit Interrupter / De-Energizing Devices**	**Vacuum Relief Mechanism**	**Initials**
	☐ Satisfactory ☐ Unsatisfactory	☐ Satisfactory ☐ Unsatisfactory	☐ Satisfactory ☐ Unsatisfactory	☐ Satisfactory ☐ Unsatisfactory	

If you require this information in an alternate format, please call 1-800-267-7120 and press 0.